

UNDERGROUND STORAGE TANK(S)

SITE NAME:

P&R Trailer Repair

REGULATED

✓

NONREGULATED

YES

NO

RELEASE CONFIRMED:

✓

CLEAN-UP INITIATED:

TANK(S) REMOVED:

✓

RELEASE UNDER CONTROL:

CLEAN-UP COMPLETED:

✓

TECHNICIAN:

UyGeg

DATE:

7/1/92

☒ USGS MAP
☒ BASE MAP
☒ ORIENTATION OF UST
☒ LENGTH OF UST 17'
☒ DIAMETER OF UST
☒ VOLUME OF UST 10K
☒ MATERIAL STORED diesel
☒ SAMPLE LOCATIONS
☒ DEPTH OF SAMPLE 15'
☒ SIDE OR (FLOOR) SAMPLE
☐ DEPTH OF TANK BURIAL
☒ HOW SAMPLE WAS COLLECTED
☒ SAMPLES PRESERVED AND TRANSPORTED cooler 4°C.
☒ TOOLS DECONTAMINATED by lab
☒ TIME/DATE SAMPLE COLLECTED
☒ TIME/DATE LAB RECEIVED
☒ LAB RESULTS <10 ppm
☒ ANALYSIS METHOD 3550, 5030
☒ C.O.C.
☒ REFERENCE TO SAMPLING POINT ON MAP
☒ CORRECT # OF SAMPLES 2 required → 3 taken
☒ WITHIN 14 DAYS HOLDING TIME FOR SAMPLES
☒ TANK DESTINATION D.H. Griffin
☒ NA DISPOSITION OF SOIL
☒ REMOVAL DATE 3-30-92
☒ COMPLETE GW/UST-2 FORM

80 gal. sludge